



Product Code

4720N/17

Strainer POLYHEDRA

2.1/8" ODS

PS = 50 bar



Product use

Inspectionable strainers can be installed in all lines of a refrigeration system, wherever it is necessary to avoid the accumulation of dirt or slag in very delicate components.

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:

HFC (R134A, R32, R404A, R407C, R410A, R507)

HFO (R1234YF, R1234ZE)

HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)

HC (R290, R600, R600A, R1270)

Product details

Attacchi ODS Ø [in.] 2.1/8"

Attacchi ODS Ø [mm] 54

Superficie filtrante [cm²] 60

Luce maglia [mm] 0,2

Kv [m³/h] 15

PS [bar] 50

TS [°C] min. -40

TS [°C] max. +150

Confezione n° pz 1