



Product Code

6120N/32

Receiver Valve
3/8" Flare - 1/4" NPT
PS = 50 bar

P  **LYHEDRA**

Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:
 HFC (R134A, R32, R404A, R407C, R410A, R507)
 HFO (R1234YF, R1234ZE)
 HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)
 HC (R290, R600, R600A, R1270)

Product details

Raccord chargement SAE Flare -

Raccords SAE Flare	3/8"
Raccords NPT	1/4"
Kv [m ³ /h]	1,35
PS [bar]	50
MWP [psi] (2)	725
TS [°C] min.	-40
TS [°C] max.	+150
Emballage	90

Notes

(1): peut être utilisé sans joint en cuivre

(2): conformément à homologation UL